



Security Construction & Equipment Committee

GPO Box 2176, Canberra ACT 2601

21 February 2006
Reference: eA977882

Australian Lock Company
17 Doyle Ave
Unanderra, NSW
2525
Attention: Garry Etchells

SCEC ENDORSEMENT OF ALCOM 5000 MORTICE LOCK

I am pleased to advise that the ALCOM 5000 latching mortice lock has been endorsed by the Security Construction and Equipment Committee (SCEC) for inclusion in the Commonwealth Security Equipment Catalogue (SEC). The endorsement rating and conditions of endorsement for the lock follow:

The ALCOM 5000 latching mortice lock has been endorsed for Secure Area (SA) applications and will be listed in the Locking Devices category of the SEC. Conditions of the endorsement for the lock are; it must be fitted with a SCEC endorsed cylinder, rated for the area for which it will be installed in, i.e. Intruder Resistant Area or Secure Area. The cylinder shall be retained in the lock using the hardened cylinder retention pins.

The endorsement is issued for the product as supplied and tested. SCEC reserves the right to re-evaluate any endorsed product at its discretion. It is the manufacturer's responsibility to contact the Chairman of SCEC if there are any changes to the product's design, operation or manufacturing process to ensure the ongoing endorsement of their product.

For inclusion in the next edition of the Security Equipment Catalogue, could you please provide an electronic image of the product, (JPEG or similar).

Any promotion or advertising of the product must not make reference to ASIO or T4 Protective Security however advertising may reference the SCEC. If you have any queries regarding this matter please contact myself direct on (02) 6234 1208.

A handwritten signature in blue ink, appearing to read 'A. Phelan'.

Andrew Phelan
for the Chairman of SCEC